

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LW422		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner WARD ESTATE Phone #						1. Well Location Fire # (if avail.)						
Mailing Address 8018 335TH AVE						Town of WHEATLAND						
City WHEATLAND State WI Zip Code 53105						Street Address or Road Name and Number 8018 335TH AVE						
County Kenosha		Co. Permit #		Notification #		Completed 11-23-1997		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) WILLIAM MANDE				Lic. # 6383		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.5598 °N -88.2164 °W			Method Code GCD013	
Address PO BOX 250 RUSSELL IL 60075				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 11 1 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? DOMESTIC USE				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #		Common Well #		Specific Capacity 1.8		Construction Type Drilled						
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method						8. Geology						
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
9 Surface 9		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				Y		GRAVEL @ SAND		Surface 48		
5 9 104						S		SANDY		48 60		
						X		SAND CLAY		60 93		
						Y C		SANS GRAVEL @ CLAY		93 100		
						Y		SAND @ GRAVEL		100 104		
6. Casing, Liner, Screen						9. Static Water Level			11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		9 ft. below ground surface			12 in. above grade			
5		SAWHILL STEEL 15 00PPF T@C A53B ASTM		Surface 104		10. Pump Test			Developed ? Yes			
Dia. (in.)		Screen type, material & slot size		From (ft.) To (ft.)		Pumping level 23 ft. below surface			Disinfected ? Yes			
						Pumping at 25 GP M for 6 Hrs.			Capped ? Yes			
						Pumping Method ?						
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?						
Method STARTER HOLE						Filled & Sealed Well(s) as needed? No NON OBSERVED						
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement								
GRANULAR BENTONITE		Surface 0										
						13. Constructor / Supervisory Driller			Lic #		Date Signed	
						WM					11-26-1997	
						Drill Rig Operator			Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		12
Building Drain - Sanitary		50	Sewer - Building Sanitary		50
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 02-23-1998

Updated On: 08-23-2019

Review Status: