

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LW550		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BENSON, WALLY					Phone # (715)866-8618		1. Well Location				Fire # (if avail.)						
Mailing Address 6598 PIKE BEND RD						Town of MINONG											
City WEBSTER					State WI		Zip Code 54893										
County Washburn		Co. Permit #		Notification #		Completed 09-28-1998		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) JAMES C LINDSTROM					Lic. # 101		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)			Method Code				
Address 105 BALSAM ST SPOONER WI 54801-9438					Well Plan Approval #			°N		°W		NW SE Section Township Range or Govt Lot # 13 42 N 13 W					
Hicap Permanent Well #					Common Well #		Specific Capacity 0.4			2. Well Type New Well							
3. Well serves 1 # of					Hicap Well ? No			of previous unique well # constructed in									
Private, potable					Hicap Property ? No			Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes					Hicap Potable ?			Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
4		Surface		241		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology							
4		ASTM A53B T&C .237 WALL 2210 P.S.I. VICTORY STEEL				Surface		241		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Q S R C T M T G		BROWN CAVING SAND RED CLAY BROWN SILT BROWN GRAVEL		Surface 65 91 230 241			
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		11. Well Is									
Surface				Surface		Surface		18 in. above grade									
9. Static Water Level																	
65 ft. below ground surface																	
10. Pump Test																	
Pumping level 106 ft. below surface																	
Pumping at 15 GP M for 24 Hrs.																	
Pumping Method ?																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller																	
CPL																	
Drill Rig Operator																	
Lic #																	
Date Signed																	
09-28-1998																	
Lic or Reg #																	
Date Signed																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Building Overhang		20
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 10-18-1999

Updated On: 10-18-1999

Review Status: