Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LW551

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LAWRENCE, DAVE	Phone #: (715)835-9613
Mailing Address: N7865 SPRINGWAY RD	
City: DANBURY	State: WI — Zip Code: 54830
County: Burnett	Co. Permit #:
Notification #	Completed: 11-14-1998
Well Constructor (Business Name): JAMES C LINDSTROM	Lic. #: 101
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 105 BALSAM ST SPOONER WI 54801-9438	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.2	

1. Well Location
Town of SCOTT
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

SE	NW	Section	Township	Range
or Govt Lot #		7	40 N	14 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	75

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		BROWN CAVING SAND	Surface	20
T		P		BROWN HARD PAN	20	46
T		M		BROWN SILT	46	66
T		Y		BROWN SAND & GRAVEL	66	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53B .237 WALL T&C 2210 PSI	Surface	71
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS	71	75

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
46 ft. below ground surface

10. Pump Test
Pumping level 56 ft. below surface
Pumping at 12 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CPL		11-14-1998
Drill Rig Operator	Lic or Reg #	Date Signed
EJL		11-14-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		20
			Septic or Holding, or POWTS Tank		55

Comment:

Created On: 10-18-1999 Updated On: 10-18-1999 Review Status: