Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LX595

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RYDELSKI TRAUDT, RITA			Phone #: (800)368-4656
Mailing Address: 900 GRACE ST			
City: ELGIN	State: IL	Zip Code: 60120	
County: Iowa	Co. Permit #:	Notification #:	Completed: 06-01-1998

Well Constructor (Business Name): DEAN E RICKARD	Lic. #: 481	Facility ID # (Public Wells):	
Address: PO BOX 499 458 WASLE LINDEN WI 53553-0499		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.4	

3. Well serves 1 # of TRAILER HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of DODGEVILLE

Fire # (if avail.):

Street Address or Road Name and Number: ESCH RD

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NE NE or Govt Lot #:	Section: 6	Township: 6 N	Range: 3 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	260
6	260	300

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	2
	H	N		HARD SANDSTONE	2	50
		N		ST PETER SANDSTONE	50	190
R		C		RED CLAY	190	215
		N	C	SANDSTONE ST PETER W CLAY LAYERS	215	250
		N		SANDSTONE	250	290
		H		SHALESTONE	290	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STD STEEL 18 97# PE WELDED ASTM A53 280WT SAWHILL	Surface	260
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	260	76 S

9. Static Water Level
160 ft. below ground surface

10. Pump Test
Pumping level 165 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DR		06-01-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JR		06-01-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 07-02-1998 Updated On: 07-02-1998 Review Status: