

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LY481		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ANO LLC						Phone # (957)566-7122		1. Well Location				Fire # (if avail.)							
Mailing Address 3000 JOHN DEERE RD						Town of RAYMOND													
City TOANO						State VA		Zip Code 23168											
County Racine		Co. Permit #		Notification # 31133285		Completed 12-24-2008		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) RUSSELL L KRIZAN				Lic. # 310		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8373 °N -87.954 °W				Method Code GCD013					
Address RUSS WELL DRILLING FRANKSVILLE WI 53126-9504				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 1 4 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Hicap Permanent Well #				Common Well #		Specific Capacity													
3. Well serves 1 # of WAREHOUSE Non-community Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		164		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - I - TOP SOIL U - C - BLUE CLAY - - L - LIMEROCK				Surface 6 81 164					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		45 ft. below ground surface				14 in. above grade					
6		ASTM-A-53 WHEATLAND PIPE 19.45 LB PER FT				Surface		81		10. Pump Test Pumping level 45 ft. below surface Pumping at 15 GP M for 24 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
BENTONITE MESH #8				Surface		91		S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RK						01-03-2009	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		35	Sewer - Building Sanitary		20
Building Overhang		8	Septic or Holding, or POWTS Tank		63

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	08/31/2011	BENTONITE CHIPS 3/4" 0-164' 47 SACKS USED	BUILDING DEMOLITION

Created On: 01-20-2009

Updated On: 07-11-2023

Review Status: