

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LY483		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHULZ, TED						Phone # (414)788-1279		1. Well Location				Fire # (if avail.)							
Mailing Address 11411 BISSONETTE DR								Town of RAYMOND											
City FRANKSVILLE						State WI		Zip Code 53126											
County Racine		Co. Permit #		Notification # 34917962		Completed 12-22-2009		Subdivision Name				Lot #							
												Block #							
Well Constructor (Business Name)				Lic. # 310		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
RUSSELL L KRIZAN								°N °W											
Address RUSS WELL DRILLING & PUMP SERVICE FRANKSVILLE WI 53126-9504				Well Plan Approval #		SE SW		Section 2		Township 4 N		Range 21 E							
								or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well											
								of previous unique well # constructed in											
								Reason for replaced or reconstructed well ?											
3. Well serves 1 # of				Hicap Well ? No				Construction Type Drilled											
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		139						Y - C -		YELLOW CLAY		Surface		25			
						Rotary - Mud Circulation				U - C -		BLUE CLAY		25		90			
						Rotary - Air				- - C G		STONEY CLAY		90		95			
						Rotary - Air & Foam				- - S -		SAND		95		105			
						Drill-Through Casing Hammer				G - N -		GRAY ROCK		105		120			
						Reverse Rotary				- - N -		SANDSTONE		120		139			
						Yes Cable-tool Bit 6in. dia...		No											
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				16 in. above grade					
6		ASTM A-53 T.C. 19.45 LB/FT TTP PIPE CO.				Surface		120		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 24 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
BENTONITE MESH #8				Surface		120				NONE									
13. Constructor / Supervisory Driller								Lic #		Date Signed									
RK										12-29-2009									
Drill Rig Operator								Lic or Reg #		Date Signed									
RK										12-29-2009									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		21	Foundation Drain to Clearwater		22
Septic or Holding, or POWTS Tank		61	Sewer - Building Sanitary		45
POWTS dispersal component (soil absorption unit or mound)		94	Clearwater Sump		24
			Wastewater Sump		55

Comment:

Created On: 01-22-2010

Updated On: 01-22-2010

Review Status: