Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LZ298

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WARGASKI, BOB			Phone #
Mailing Address: 30353 DOWELL RD			
City: MC HENRY	State: IL	Zip Code: 60058	
County: Forest	Co. Permit #	Notification #	Completed: 10-09-2001

Well Constructor (Business Name): PETER ROMITTI JR	Lic. #: 466	Facility ID # (Public Wells)	
Address: PO BOX 153 NIAGARA WI 54151-0153		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ARMSTRONG CREEK				Fire # (if avail.): 116
Street Address or Road Name and Number: KUS RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 45.64805 °N -88.42713 °W				Method Code: GPS008
NE NE or Govt Lot #	Section: 36	Township: 47 N	Range: 16 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	104

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	C	SAND, BOULDER	Surface	70
-	N	S	-	FINE SAND	70	104

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B P.E. IPSCO 280	Surface	100
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	S.S.	100	104

9. Static Water Level
55 ft. below ground surface

10. Pump Test
Pumping level 75 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JR		10-10-2001
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BH		10-16-2001

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 10-31-2001 Updated On: 08-25-2022 Review Status: