

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MA427		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner SEITZ, DONNA					Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address N4915 MEYER RD					Town of LISBON					N4915						
City NEW LISBON					State WI		Zip Code 53950					Street Address or Road Name and Number N4915 MEYER RD				
County Juneau		Co. Permit #		Notification #			Completed 11-21-1997			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) RAYMOND J LUDWIG				Lic. # 316		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8191 °N -90.0818 °W				Method Code GCD013		
Address N7644 10TH AVE NEW LISBON WI 53950-0052				Well Plan Approval #				SW SE		Section 36		Township 16 N		Range 3 E		
				Approval Date (mm-dd-yyyy)				or Govt Lot #		36		16 N		3 E		
Hicap Permanent Well #			Common Well #			Specific Capacity 1.4			2. Well Type New Well							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No			Reason for replaced or reconstructed well ? Construction Type Drilled							
						Hicap Property ? No										
						Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
6		Surface		70		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
Y S N				SAND YELLWO SANDSTONE				Surface 34		34 70						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		BLACK STEEL P E ASTM A53 18 97 LBS FT 280 WALLSAWHILL				Surface		37								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material Method																
9. Static Water Level 21 ft. below ground surface																
10. Pump Test Pumping level 32 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?																
11. Well Is 16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE																
13. Constructor / Supervisory Driller										Lic #		Date Signed				
RL										11-29-1997		Drill Rig Operator				
Lic or Reg #										Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		16

Comment:

Created On: 03-17-1998

Updated On: 05-04-2020

Review Status: