

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MA506		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner IGLESIAS, LOU						Phone # (608)223-1340		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 23						Town of DEKORRA						Street Address or Road Name and Number			
City DE FOREST				State WI		Zip Code 53532									
County Columbia		Co. Permit #		Notification #		Completed 08-11-1997		Subdivision Name EAGLE BLUFF			Lot # 5		Block #		
Well Constructor (Business Name) ZOELLNER CENTRAL WELL DRILLING				Lic. # 4231		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code				
Address PO BOX 405 BRANDON WI 53919-0405				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Township 11 N		Range 8 E			
								SW NW Section 12							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4		2. Well Type New Well							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		of previous unique well # constructed in							
								Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 205			Yes Rotary - Mud Circulation												
6 205 219			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
			Removed? ___ depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		NEW BLACK STEEL 1897 #PER FT 1780 PSI API5L GR BPE USA IPSCO				Surface		205							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...					
7. Grout or Other Sealing Material										9. Static Water Level				11. Well Is	
Method										32 ft. below ground surface				12 in. above grade	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
MUD @ CUTTINGS		Surface		205				Pumping level 50 ft. below surface							
										Pumping at 25 GP M for 1 Hrs.					
										Pumping Method ?					
										12. Notified Owner of need to fill & seal ?					
										Filled & Sealed Well(s) as needed?					
										NA					
13. Constructor / Supervisory Driller								Lic #		Date Signed					
TRO										08-11-1997					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		17

Comment:

Created On: 10-17-1997

Updated On: 10-17-1997

Review Status: