

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MA987		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner SIPPLE, RICHARD						Phone # (715)336-2283		1. Well Location				Fire # (if avail.)		
Mailing Address N18439 10 ACRE						Town of GOODMAN						Street Address or Road Name and Number GOODMAN INDUSTRIAL PK		
City GOODMAN				State WI		Zip Code 54125								
County Marinette		Co. Permit #		Notification #		Completed 09-28-1998		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) KLEIMAN PUMP @ WELL DRILLING INC				Lic. # 575		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address PO BOX 704 IRON MOUNTAIN MI 49801-0704				Well Plan Approval #		NE SE		Section 33		Township 37 N		Range 17 E		
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2		2. Well Type New Well						
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?						
Private, potable				Hicap Potable ?		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		84		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
V G G				GRAVEL @ BOULDERS HARD N CAVING				Surface		20				
Q G M				SILTY GRAVEL @ CABLE CAVING				20		65				
G Z M				CLAY GRAVEL GRAY SILTY				65		78				
Q G				CLEANER GRAVEL CAVING				78		84				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		NEW BLACK STEEL 18 97# FT A53 SAWHILL USE PE WELD				Surface		82						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		SS COOKS 100 SLOT K PACKER				82		84						
7. Grout or Other Sealing Material														
Method KEPT MOUND WITH GRANULAR BENTO														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
5 BAGS GRANULAR BENTONITE				Surface		82		5 S						
9. Static Water Level														
29 ft. below ground surface														
10. Pump Test														
Pumping level 75 ft. below surface														
Pumping at 9 GP M for 1 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
DN								Lic #		Date Signed 09-29-1998				
Drill Rig Operator								Lic or Reg #		Date Signed 09-29-1998				
DN														

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-02-1998

Updated On: 10-24-2002

Review Status: