Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MA987

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SIPPLE, RICHARD	Phone #: (715)336-2283
Mailing Address: N18439 10 ACRE	
City: GOODMAN	State: WI — Zip Code: 54125
County: Marinette	Co. Permit #: — Notification #: — Completed: 09-28-1998
Well Constructor (Business Name): KLEIMAN PUMP @ WELL DRILLING INC	Lic. #: 575 — Facility ID # (Public Wells):
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of GOODMAN

Fire # (if avail.):

Street Address or Road Name and Number: GOODMAN INDUSTRIAL PK

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SE or Govt Lot #: — Section: 33 — Township: 37 N — Range: 17 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of WELDING SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	84

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	G	G	GRAVEL @ BOULDERS HARD N CAVING	Surface	20
	Q	G	M	SILTY GRAVEL @ CABLE CAVING	20	65
G		Z	M	CLAY GRAVEL GRAY SILTY	65	78
	Q	G		CLEANER GRAVEL CAVING	78	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97# FT A53 SAWHILL USE PE WELD	Surface	82
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS COOKS 100 SLOT K PACKER	82	84

9. Static Water Level

29 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 9 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method KEPT MOUND WITH GRANULAR BENTO

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
5 BAGS GRANULAR BENTONITE	Surface	82	5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DN		09-29-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DN		09-29-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-02-1998 Updated On: 10-24-2002 Review Status: