Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MA989

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MENDINI, MARK	Phone #: (715)528-4822
Mailing Address: PO BOX 211	
City: FLORENCE	State: WI — Zip Code: 54121
County: Florence	Co. Permit #: — Notification #: — Completed: 10-13-1998
Well Constructor (Business Name): KLEIMAN PUMP @ WELL DRILLING INC	Lic. #: 575 — Facility ID # (Public Wells):
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of FLORENCE

Fire # (if avail.):

Street Address or Road Name and Number: KK RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW — Section: 24 — Township: 40 N — Range: 17 E

or Govt Lot #:

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	81

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	X		CLAY SAND NONCAVING	Surface	3
	V	H		SLATE RED GRAY NON CAVING	3	56
	B	Q		RED WHITE QUARTZ BROKEN	56	62
R		H		SLATE RED GRAY	62	81

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 BLACK STEEL WELDED 280 SAWHILL 18 97# FT	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 13 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method DISPLACEMENT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT GROUT	Surface	42	6 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DR		10-13-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DR		10-13-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-18-1998 Updated On: 11-18-1998 Review Status: