Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MA991

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVIS, DONALD	Phone #: (715)589-3250
Mailing Address: HC 1 BOX 566	
City: FLORENCE	State: WI — Zip Code: 54121
County: Florence	Co. Permit #: — Notification #: — Completed: 10-13-1998
Well Constructor (Business Name): KLEIMAN PUMP @ WELL DRILLING INC	Lic. #: 575 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: PO BOX 704 IRON MOUNTAIN MI 49801-0704	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.5	

1. Well Location

Town of HOMESTEAD

Fire # (if avail.):

Street Address or Road Name and Number: HOMESTEAD RD

Subdivision Name: — Lot #: — Block #: —

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SE — Section: 11 — Township: 38 N — Range: 18 E

or Govt Lot #:

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

DRY YEAR OLD PITWELL SLOW

Construction Type: Drilled

3. Well serves 1 # of BARN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	75

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		CLEAN CAVY SAND BROWN	Surface	15
	V	C		RED CLAY NONCAVING	15	65
	Q	S		SAND BROWN CAVY CLEAN	65	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL IPSCO 18 97# A53 PE WELDED	Surface	71
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	S S JOHNSON 10 SLOT W W	71	75

7. Grout or Other Sealing Material

Method KEPT WOUND WITH GRAN BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	71	5 S

9. Static Water Level

48 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DN		10-14-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DN		10-14-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		125	Building Overhang		90
			Septic or Holding, or POWTS Tank		150

Comment:

Created On: 11-18-1998 Updated On: 11-18-1998 Review Status: