Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MC074

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STONER, GLADYS			Phone #: (937)399-3890
Mailing Address: 311 LINWOOD			
City: STEVENS POINT	State: WI	Zip Code: 54481	
County: Portage	Co. Permit #:	Notification #:	Completed: 05-08-1998

Well Constructor (Business Name): CHETS PLBG @ HTG INC	Lic. #: 4832	Facility ID # (Public Wells):	
Address: 5009 COYE DR STEVENS POINT WI 54481-5001		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Village of PARK RIDGE

Fire # (if avail.):

Street Address or Road Name and Number: 311 LINWOOD AVE

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SE NW or Govt Lot #	Section: 34	Township: 24 N	Range: 8 E

2. Well Type New Well — YR399 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
OLD WELL IN BASEMENT

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV 2 WELL PIPE	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	ST ST 10 SLOT	37	40

7. Grout or Other Sealing Material
Method

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	40

9. Static Water Level
26 ft. below ground surface

10. Pump Test
Pumping level 5 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PL		05-12-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		8	Downspout/Yard Hydrant		11
Building Overhang		2	Sewer - Building Sanitary		10

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	03/15/2017	NEAT CEMENT 0-40' 1 SACK	POINT FAILED

Created On: 07-02-1998 Updated On: 04-19-2017 Review Status: