

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MF170		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FRANGQUIST, LEE						Phone # (920)494-1647		1. Well Location				Fire # (if avail.)			
Mailing Address 1423 SERVAIS ST						Town of SILVER CLIFF									
City GREEN BAY						State WI		Zip Code 54304							
County Marinette		Co. Permit #		Notification #		Completed 08-17-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) MORIN@JOHNSON WELL DRILLING				Lic. # 6317		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address W8855 PROVENCHER RD NIAGARA WI 54151				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		NE NW Section Township Range or Govt Lot # 32 34 N 18 E					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT NOT ENOUGH WATER									
3. Well serves 1 # of HOMES Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
6		Surface		53		Yes Rotary - Mud Circulation				Geology Codes S C		Type, Caving/Noncaving, Color, Hardness, etc... CLAYISH SAND			
6		53		224		Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				From (ft.) To (ft.) Surface 78 78 224					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is			
6		ASTM A53B SAWHILL 280 18 97 LB FT WELDED				Surface		78		20 ft. below ground surface		24 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes			
										Pumping level 200 ft. below surface Pumping at 2 GP M for 1 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material															
Method MID VOTANY															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
DRILL SLURRY		Surface		53		3 S		Filled & Sealed Well(s) as needed? No STILL IN USE							
13. Constructor / Supervisory Driller															
MJ												Lic #		Date Signed 08-24-1998	
Drill Rig Operator												Lic or Reg #		Date Signed	
DJM														08-24-1998	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	POWTS dispersal component (soil absorption unit or mound)	>	50
Septic or Holding, or POWTS Tank	>	50	Privy		82

Comment:

Created On: 09-17-1998

Updated On: 09-17-1998

Review Status: