

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MF172		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner CHRZANOWSKI, JIM						Phone # (414)677-9117		1. Well Location				Fire # (if avail.)					
Mailing Address W200 N16445 PINE DR						Town of STEPHENSON											
City JACKSON						State WI		Zip Code 53037									
County Marinette		Co. Permit #		Notification #		Completed 08-21-1998		Street Address or Road Name and Number DOE TRL									
Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) MORIN@JOHNSON WELL DRILLING				Lic. # 6317		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address W8855 PROVENCHER RD NIAGARA WI 54151				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 8 33 N 19 E											
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 1.7									
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?											
Heat Exchange ___ # of drillholes				Construction Type Drilled													
3. Well serves # of Private, potable																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology							
6		Surface		70		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
										Q G G		GRAVEL STONES CAVING		Surface 15			
										M S		SAND CLEAN MEDIUM		15 70			
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is					
6		ASTM A53B SAWHILL 280 W 18 97 LB FT WELDED				Surface		64		50 ft. below ground surface		18 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes					
6		#12 6 FT TELESCOPING				64		70		Pumping level 56 ft. below surface		Disinfected ? Yes					
										Pumping at 10 GP M for 2 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												MJ				08-24-1998	
												Drill Rig Operator		Lic or Reg #		Date Signed	
												DJ				08-24-1998	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		50	Sewer - Building Sanitary		50
Building Overhang		20	Septic or Holding, or POWTS Tank	>	80

Comment:

Created On: 09-17-1998

Updated On: 09-17-1998

Review Status: