Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MF176

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BROOKS, VANCE			Phone #: (715)646-6341
Mailing Address: PO BOX 66			
City: LONG LAKE	State: WI	Zip Code: 54542	
County: Florence	Co. Permit #:	Notification #:	Completed: 09-02-1998

Well Constructor (Business Name): MORIN@JOHNSON WELL DRILLING	Lic. #: 6317	Facility ID # (Public Wells):	
Address: W8855 PROVENCHER RD NIAGARA WI 54151		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0	

3. Well serves 1 # of CAMP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LONG LAKE

Fire # (if avail.):

Street Address or Road Name and Number: HALSEY LAKE RD

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SE NE or Govt Lot #:	Section: 10	Township: 39 N	Range: 15 E

2. Well Type Replacement
of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?
POINT WENT DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	78
6	78	300

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	H	G	G	HARD GRAEL STONES	Surface	76
		Q		MULTI COLOR GRANITE	76	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B SAWHILL 280 W 18 97# FT WELDED	Surface	78
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MID ROTARY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	78	4 S

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 2 GP M for 48 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
OWNER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJM		09-14-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Shoreline/Pool	>	100
Building Overhang		26	Septic or Holding, or POWTS Tank		64

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	09/02/1998	YIELD BEFORE DRY HOLE AFTER 2 GPM

Created On: 10-13-1998 Updated On: 10-15-2026 Review Status: