Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MF273

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BYLASKA, BARBARA			Phone #: (715)623-6233
Mailing Address: 4631 HANSEN RD			
City: ANTIGO	State: WI	Zip Code: 54409	
County: Marathon	Co. Permit #:	Notification #:	Completed: 11-05-1997

1. Well Location

Town of HARRISON

Fire # (if avail.):

Street Address or Road Name and Number: 4631 HANSEN RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DANIEL DILLENBURG	196	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW	SE	Section	Township	Range
or Govt Lot #		2	30 N	10 E

Well Plan Approval #:

Address: W9618 ANGLE RD, SHAWANO WI 54166

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in 97

Hicap Permanent Well #	Common Well #	Specific Capacity
		0

Reason for replaced or reconstructed well ?: OLD WELL IN PIT

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	42
6	42	305

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	11
Q	GRANITE	11	305

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 18 97 SAWHILL WELDED	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 250 ft. below surface

Pumping at 0.5 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	42	8 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		11-20-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
		11-20-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		96

Type	Qualifier	Distance
Building Overhang		34
Septic or Holding, or POWTS Tank		73

Comment:

Created On: 03-11-1998 Updated On: 10-15-2026 Review Status: