Well Construction Report
WISCONSIN UNIQUE WELL NUMBER

MF275

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRETZ, DANIEL	Phone #: (715)623-7904
Mailing Address: 325 MOURNING DOVE LN	
City: ANTIGO	State: WI — Zip Code: 54409
County: Langlade	Co. Permit #:
Notification #	Completed: 10-31-1997

1. Well Location

Town of ANTIGO

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): DANIEL DILLENBURG	Lic. #: 196	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code
Well Plan Approval #			SW NE or Govt Lot #:	Section: 26 — Township: 31 N — Range: 11 E
Address: W9618 ANGLE RD, SHAWANO WI 54166		Approval Date (mm-dd-yyyy)		
Hicap Permanent Well #	Common Well #	Specific Capacity: 4.2		

2. Well Type New Well

of previous unique well # constructed in 97

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	17
		Y	C	SAND GRAVEL @ BOULDERS	17	78
		S		SAND	78	158
		Y	M	SILTY SAND @ GRAVEL	158	170
		Y		SAND GRAVEL	170	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 18 97 SAWHILL WELDED	Surface	175
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 20 SLOT	175	185

9. Static Water Level

147 ft. below ground surface

10. Pump Test

Pumping level 159 ft. below surface

Pumping at 50 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENSEAL MOUNDED	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		11-20-1997
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		65

Comment:

Created On: 03-06-1998 Updated On: 03-06-1998 Review Status: