

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MF275		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KRETZ, DANIEL				Phone # (715)623-7904		1. Well Location				Fire # (if avail.)									
Mailing Address 325 MOURNING DOVE LN						Town of ANTIGO													
City ANTIGO						State WI		Zip Code 54409											
County		Co. Permit #		Notification #		Completed 10-31-1997		Subdivision Name				Lot #							
Langlade								Block #											
Well Constructor (Business Name) DANIEL DILLENBURG				Lic. # 196		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address W9618 ANGLE RD SHAWANO WI 54166				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 26 31 N 11 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 4.2		2. Well Type New Well					of previous unique well # constructed in 97						
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?											
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		185		Rotary - Mud Circulation				S		SAND		Surface		17			
						Yes Rotary - Air				Y C		SAND GRAVEL @ BOULDERS		17		78			
						Rotary - Air & Foam				S		SAND		78		158			
						Drill-Through Casing Hammer				Y M		SILTY SAND @ GRAVEL		158		170			
						Reverse Rotary				Y		SAND GRAVEL		170		185			
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		147 ft. below ground surface		22 in. above grade							
6		ASTM A53 18 97 SAWHILL WELDED				Surface		175		10. Pump Test		Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 159 ft. below surface		Disinfected ? Yes							
6		JOHNSON STAINLESS STEEL 20 SLOT				175		185		Pumping at 50 GP M for 2 Hrs.		Capped ? Yes							
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?		No							
BENSEAL MOUNDED				Surface		0				NONE									
												13. Constructor / Supervisory Driller		Lic #		Date Signed			
												DD				11-20-1997			
												Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		65

Comment:

Created On: 03-06-1998

Updated On: 03-06-1998

Review Status: