

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MG954		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MILLER, JOHN						Phone # (715)256-1570		1. Well Location				Fire # (if avail.)			
Mailing Address 518 CENTER ST						Town of WAUPACA						Street Address or Road Name and Number BUNKER HILL RD			
City WAUPACA				State WI		Zip Code 54981									
County Waupaca		Co. Permit #		Notification #		Completed 08-13-2000		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) VETTER WATER SYSTEMS				Lic. # 6520		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address E808 MYNARD RD WAUPACA WI 54981				Well Plan Approval #				°N		°W		SW SE Section Township Range or Govt Lot # 32 22 N 12 E			
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No											
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		202		Rotary - Mud Circulation				Rotary - Air					
6		Surface		202		Rotary - Air & Foam				Drill-Through Casing Hammer					
						Reverse Rotary				Cable-tool Bit ___ in. dia...					
						Dual Rotary				Temp. Outer Casing ___ in. dia					
						Removed? ___ depth ft. (If NO explain on back side)									
						Yes				No					
						Upper Enlarged Drillhole				Lower Open Bedrock					
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - Y G				SAND, GRAVEL & BOULDERS				Surface		150					
- - Y -				LARGE SAND & GRAVEL				80		202					
- - C -				CLAY				150		180					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 50 ft. below ground surface					
6		6.625 X 280 WELDED JOINT IPSCO				Surface		198							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 90 ft. below surface Pumping at 50 GP M for 1 Hrs. Pumping Method ?					
6		#5 SLOT 3'				198		202							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
BENTONITE				Surface		202		2 S							
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? N/A															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
SH								Lic or Reg #		08-15-2000					
Drill Rig Operator								Lic or Reg #		Date Signed					
WV								Lic or Reg #		08-15-2000					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang	>	10
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-26-2001

Updated On: 06-26-2001

Review Status: