

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	>	20	Foundation Drain to Clearwater	>	12
Building Overhang	>	12	Foundation Drain to Sewer	>	20
Clearwater Sump	>	25	Landfill	>	637
Downspout/Yard Hydrant	>	12	Sewer - Building Sanitary	>	20

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Landfill Variance	01/06/1998	< REQUIRED 1200' FROM LANDFILL

Created On: 01-11-1999

Updated On: 10-24-2002

Review Status: