

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MH265		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner D @ P BUILDERS INC, RAY						Phone # (414)966-7299		1. Well Location				Fire # (if avail.)			
Mailing Address N68 W33780 HWY K						Town of DELAFIELD									
City OCONOMOWOC						State WI		Zip Code 53066				Street Address or Road Name and Number N37 W29144 MIDDLEFIELD RD			
County Waukesha		Co. Permit #		Notification #		Completed 08-20-1998		Subdivision Name STILL MEADOW				Lot # 79		Block #	
Well Constructor (Business Name) D @ D DRILLING CO INC				Lic. # 119		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.0865 °N -88.3268 °W				Method Code GCD013			
Address 36110 THOMAS DR OCONOMOWOC WI 53066				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 11 7 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONST							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
6		Surface		134		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Y Y SAND @ GRAVEL YELLOW Surface 35 T C G GRAVELLY CLAY BROWN 35 98 N S SAND YELLOW FINE 98 134					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		NEW BLK 18 97 PLAIN END ASTM A53 MFG SAWHILL				Surface		131		98 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
6		S S SCREEN #12 SLOT				131		134		16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material Method															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
CJ										08-25-1998					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Downspout/Yard Hydrant		20
Clearwater Sump		30	Foundation Drain to Clearwater		20
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		40

Comment:

Created On: 01-07-1999

Updated On: 07-12-2019

Review Status: