

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MH266		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JANE KERWIN HOMES						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 5625 GROVE TERR						Town of MERTON						Street Address or Road Name and Number							
City GREENDALE				State WI		Zip Code 53129													
County Waukesha		Co. Permit #		Notification #		Completed 09-14-1998		Subdivision Name TOMLON RDG				Lot # Block #							
Well Constructor (Business Name) D @ D DRILLING CO INC				Lic. # 119		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 36110 THOMAS DR OCONOMOWOC WI 53066				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 14 8 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Approval Date (mm-dd-yyyy)				Hicap Permanent Well # Common Well # Specific Capacity 10															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		116		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Y Y SAND @ GRAVEL YELLOW Surface 48 T C G GRAVELLY CLAY BROWN 48 103 Y S SAND YELLOW 103 116		116		116							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		91 ft. below ground surface				14 in. above grade					
6		NEW BLK 18 97 PLAIN END ASTM A 50 MFG IPSCO				Surface		113		10. Pump Test Pumping level 93 ft. below surface Pumping at 20 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
SS SCREEN						113		116											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												CJ				09-18-1998			
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		55	Downspout/Yard Hydrant		55
Clearwater Sump		65	Foundation Drain to Clearwater		55

Comment:

Created On: 01-07-1999

Updated On: 01-07-1999

Review Status: