Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MH268

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PANTAZON, RAY	Phone #: (920)474-7495
Mailing Address: N79 W34857 PETERSON	
City: OCONOMOWOC	State: WI — Zip Code: 53066
County: Waukesha	Co. Permit #:
Notification #	Completed: 08-27-1998
Well Constructor (Business Name): D @ D DRILLING CO INC	Lic. #: 119
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 36110 THOMAS DR OCONOMOWOC WI 53066	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 5	

1. Well Location

Town of OCONOMOWOC

Fire # (if avail.)

Street Address or Road Name and Number: W349 N8300 NORWEIGAN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.1705 °N -88.4361 °W	GCD013

NW SW or Govt Lot #	Section	Township	Range
	12	8 N	17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW CONST

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	62

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		Y		SAND @ GRAVEL YELLOW	Surface	34
G		C	G	GRAVELLY CLAY GRAY	34	59
G		G		GRAVEL GREY	59	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK 18 97 PLAIN END ASTMA53 MFG SAWHILL	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 20 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJ		09-10-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		18
Foundation Drain to Clearwater		20
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-07-1999 Updated On: 07-12-2019 Review Status: