

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MJ140		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																					
Property Owner VANDERMAUSE, TIM						Phone #		1. Well Location				Fire # (if avail.)																			
Mailing Address 5562 DELCORE RD						Town of GREEN BAY						5562																			
City NEW FRANKEN						State WI		Zip Code 54228				Street Address or Road Name and Number DELCORE RD																			
County Brown		Co. Permit #		Notification #		Completed 07-16-1998		Subdivision Name				Lot #		Block #																	
Well Constructor (Business Name) CHARLIES PUMPS @ WELL DRILLING I				Lic. # 143		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5589 °N -87.8017 °W				Method Code GCD013																	
Address 9504 CNTY D FORESTVILLE WI 54213				Well Plan Approval #		NE NW		Section 14		Township 24 N		Range 22 E		2. Well Type Replacement																	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				or Govt Lot #				of previous unique well #		constructed in 98															
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				REPLACE DUG WELL				Construction Type Drilled																	
Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?				4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method														8. Geology																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
9.875		Surface		41		Yes Rotary - Mud Circulation				Yes Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		CLAY		Surface		6	
6		41		103		Rotary - Air				Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		CLAY @ GRAVEL		6		17			
6		41		103		Rotary - Air				Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		CLAY		17		26			
6		41		103		Rotary - Air				Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		GRAVEL		26		35			
6		41		103		Rotary - Air				Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		LIMESTONE		35		103			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. below ground surface				14 in. above grade																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		10. Pump Test				Developed ? Yes																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?				12. Notified Owner of need to fill & seal ?																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		Filled & Sealed Well(s) as needed?				No																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		IN USE				13. Constructor / Supervisory Driller																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		Lic #				Date Signed																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		07-29-1998				Drill Rig Operator																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		Lic or Reg #				Date Signed																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		08-01-1998				RM																	
6		SAWHILL USA A53 GR B API 5L 18 97 WELDED JOINTS 21NEW BLACK 6 5 8 PE				Surface		41		08-01-1998				RM																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		64	Animal Barn Pen		192
Building Drain - Sanitary		35	Silo/Storage Tube		250
Building Overhang		12	Animal Yard - Include Hutches		140
Collector Sewer - San or Storm		108	Barn Gutter		202
Sewer - Building Sanitary		48	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 09-30-1998

Updated On: 11-21-2019

Review Status: