

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MK452		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GREEN BAY						Phone # (920)448-3480		1. Well Location				Fire # (if avail.)		
Mailing Address 631 S ADAMS ST						City of GREEN BAY								
City GREEN BAY				State WI		Zip Code 54305								
County Brown		Co. Permit #		Notification #		Completed 06-30-2000		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) LAYNE NORTHWEST				Lic. # 2400		Facility ID # (Public Wells)				Method Code GPS008				
Address W229N5005 DUPLAINVILLE RD PEWAUKEE WI 53072				Well Plan Approval #		or Govt Lot #		Section 14		Township 24 N		Range 20 E		
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well				
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?				
3. Well serves 1 # of TEST WELL				Hicap Potable ? No		Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
12		Surface		192		No Rotary - Mud Circulation				No				
8		192		815		Yes Rotary - Air				No				
						No Rotary - Air & Foam				No				
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia...				No				
						No Dual Rotary				No				
						Yes Temp. Outer Casing 12in. dia								
						No Removed? 92depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
D		D-DRIFT						Surface		90				
L		L-LIMESTONE/DOLOMITE						90		383				
N		N-SANDSTONE						383		811				
Q		Q-GRANITE						811		815				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				
12		NEW BL STEEL PE WELDED A53 49.5LB SAWHILL				Surface		92		11. Well Is				
8		NEW BL STEEL PE WELDED A-53 28.55 LB SAWHILL				0		190		36 in. above grade				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				
										Developed ? Yes				
										Disinfected ? Yes				
										Capped ? Yes				
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ? No				
Method BRADENHEAD										Filled & Sealed Well(s) as needed? No				
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
NEAT CEMENT		Surface		190		80								
13. Constructor / Supervisory Driller										Lic #		Date Signed		
BM												08-03-2000		
Drill Rig Operator										Lic or Reg #		Date Signed		
DH												08-03-2000		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: TEST WELL GB #10 ASR PROJECT

Abandonment Type	Abandonment Date	Procedure	Reason
	08/07/2018	NEAT GROUT 0-587FT (202), CHLORINATED PEA STONE 587-815FT (3.5 YARDS)	END OF USE

Created On: 10-04-2023

Updated On: 10-04-2023

Review Status: APPROVED