Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MM388

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRAUS BUILDERS			Phone #: (608)837-0324
Mailing Address: 711 LOIS DR PO BOX 3			
City: SUN PRAIRIE	State: WI	Zip Code: 53590	
County: Marquette	Co. Permit #:	Notification #:	Completed: 09-03-1999

Well Constructor (Business Name): BRADLEY S WEBSTER	Lic. #: 614	Facility ID # (Public Wells):	
Address: N2323 PINE HOLLOW RD POYNETTE WI 53955-9620		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.3	

1. Well Location

Town of HARRIS

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SW SE or Govt Lot #:	Section: 1	Township: 16 N	Range: 9 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 3 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	146

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S		CAVING SAND	Surface	115
	Y		SAND & GRAVEL	115	127
H	N		FIRM SANDSTONE	127	146

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P-E SAWHILL A53B .280 WALL	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 40 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NONE	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		08-04-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RW		08-04-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Landfill	>	1200
			Sewer - Building Sanitary		20

Comment:

Created On: 04-12-2000 Updated On: 04-12-2000 Review Status: