Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MM392

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: POTENBURG, MICHELLE			Phone #
Mailing Address: 3069 VINBORN RD			
City: SUN PRAIRIE	State: WI	Zip Code: 53590	
County: Dane	Co. Permit #: 16061	Notification #	Completed: 09-28-1999

1. Well Location

Fire # (if avail.)

Town of BRISTOL

Street Address or Road Name and Number: 3069 VINBORN RD

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
BRADLEY S WEBSTER	614	

Latitude / Longitude in Decimal Degree (DD): 43.2382 °N -89.2387 °W

Method Code: GCD013

Well Plan Approval #

NE	NW	Section	Township	Range
or Govt Lot #		19	9 N	11 E

Address: N2323 PINE HOLLOW RD
POYNETTE WI 53955-9620

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		2

Reason for replaced or reconstructed well ?

OLD WELL COLLAPSED

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	80
6	80	165

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	18
		L		LIMESTONE	18	120
	H	N		FIRM SANDSTONE	120	165

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE SAWHILL A53B .280 WALL	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

84 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: PRESSURE TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	80	24 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BW		09-10-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RW		09-30-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150
Building Overhang		25
Landfill	>	1200
Sewer - Building Sanitary		70
Septic or Holding, or POWTS Tank		120

Comment:

Created On: 02-22-2000 Updated On: 12-11-2019 Review Status: