Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MN303

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRANIG, THOMAS	Phone #: (715)824-2912
Mailing Address: 4731 CTY HY K	
City: AMHERST	State: WI — Zip Code: 54406
County: Portage	Co. Permit #: — Notification #: — Completed: 06-02-1998
Well Constructor (Business Name): ALPHA DRILLING SERVICES INC	Lic. #: 6182 — Facility ID # (Public Wells):
Address: 8658 RILEY RD, AMHERST WI 54406	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 9

1. Well Location

Town of STOCKTON

Fire # (if avail.):

Street Address or Road Name and Number: 4731 CTY HWY K

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.4437 °N -89.3739 °W — Method Code: GCD013

SE NW or Govt Lot #: — Section: 26 — Township: 23 N — Range: 9 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	95

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Y	U		DIRTY SAND @ STONES	Surface	11
	Y	G		SAND @ GRAVEL COBBLES	11	25
A	G	G		COARSE GRAVEL @ BOULDERS	25	67
	Y			SAND @ GRAVEL	67	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6 625 X 280 PE WELDED JOINT A53B SAWHILL	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPING SS 10 SLOT	91	95

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	91	

9. Static Water Level

64 ft. below ground surface

10. Pump Test

Pumping level 66 ft. below surface

Pumping at 18 GP M for 1.5 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
EG		06-03-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		125
Building Overhang		9

Type	Qualifier	Distance
Wastewater Sump		47
Septic or Holding, or POWTS Tank		125

Comment:

Created On: 09-18-1998 Updated On: 05-07-2020 Review Status: