

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MO387		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ZONDA, DAVE @ BONNIE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 7020 HWY W						Town of ADDISSON						7020	
City ALLENTON						State WI		Zip Code 53002				Street Address or Road Name and Number 7020 HWY W	
County Washington		Co. Permit #		Notification #		Completed 09-02-1998		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) KLEMME BROS WELL @ PUMP INC				Lic. # 5935		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4463 °N -88.3413 °W			
Address 4932 HWY H KEWASKUM WI 53040				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 3 11 N 18 E		Method Code GCD013					
				Approval Date (mm-dd-yyyy)		2. Well Type New Well							
Hicap Permanent Well #				Common Well #		Specific Capacity 3		of previous unique well # constructed in					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ?							
						Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)										
6 20 225													
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
X G			CLAY SAND @ GRAVEL						Surface 8				
S			SAND						8 48				
X			CLAY @ SAND						48 105				
C			CLAY						105 160				
X			CLAY SAND						160 190				
S			SAND						190 218				
Y			SAND @ GRAVEL						218 225				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level					
6		IPSCO 1897 A53 WELDED				Surface 225		35 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test					
								Developed ? Yes Disinfected ? Yes Capped ? Yes					
								Pumping level 40 ft. below surface Pumping at 15 GP M for 12 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		11. Well Is							
CLAY SLURRY		Surface 20				18 in. above grade Filled & Sealed Well(s) as needed? WAS NONE							
12. Notified Owner of need to fill & seal ?													
13. Constructor / Supervisory Driller Lic # Date Signed													
GK 09-30-1998													
Drill Rig Operator Lic or Reg # Date Signed													
13. Constructor / Supervisory Driller Lic # Date Signed													
GK 09-30-1998													
Drill Rig Operator Lic or Reg # Date Signed													
GK 09-30-1998													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	70	Downspout/Yard Hydrant	>	10
Building Drain - Sanitary	>	30	Foundation Drain to Clearwater	>	12
Building Overhang		12	Sewer - Building Sanitary	>	30
Clearwater Sump	>	30	Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-20-1998

Updated On: 07-08-2019

Review Status: