

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MO388		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner POOLE, TOM						Phone #									
Mailing Address 8960 TOWNLINE RD						Town of KEWASKUM						Fire # (if avail.) 8960			
City KEWASKUM				State WI		Zip Code 53040				Street Address or Road Name and Number 8960					
County Washington		Co. Permit #		Notification #		Completed 09-23-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) KLEMME BROS WELL @ PUMP INC				Lic. # 5935		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 4932 HWY H KEWASKUM WI 53040				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 7 12 N 19 E		Approval Date (mm-dd-yyyy)				2. Well Type New Well of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?				Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 42			Rotary - Mud Circulation												
6 42 170			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			<u>Yes</u> Cable-tool Bit 10in. dia...												
			Dual Rotary												
			<u>Yes</u> Temp. Outer Casing 10in. dia												
			<u>Yes</u> Removed? ___depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ISPCO 18 97 A53 WELDED				Surface		42							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		42		22							
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
C		CLAY				Surface		6							
Y		SAND @ GRAVEL				6		28							
T L		LIME TAN				28		42							
I L		LIME WHITE				42		170							
9. Static Water Level															
35 ft. below ground surface															
10. Pump Test															
Pumping level 35 ft. below surface															
Pumping at 15 GP M for 24 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
GK				Lic #		Date Signed 09-30-1998									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Downspout/Yard Hydrant	>	40
Clearwater Sump	>	60	Sewer - Building Sanitary	>	40
			Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-20-1998

Updated On: 10-20-1998

Review Status: