Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MO682

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WOLFE, JASON	Phone #: (715)659-4189
Mailing Address: S3146 STATE RD 13	
City: SPENCER	State: WI — Zip Code: 54479
County: Clark	Co. Permit #: — Notification #: — Completed: 09-29-1998
Well Constructor (Business Name): KLINE WELL @ PUMP INC	Lic. #: 6010 — Facility ID # (Public Wells):
Address: PO BOX 176 LOYAL WI 54446	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1.2	

1. Well Location

Town of UNITY

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW or Govt Lot # — Section: 28 — Township: 27 N — Range: 1 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	20
6	20	130

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	10
		Y		SAND @ GRAVEL	10	50
		Z		CLAY @ GRAVEL	50	55
		Y		SAND @ GRAVEL	55	95
	D	Q		DECOMPOSED GRANITE	95	118
		Q		GRANITE	118	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18 97LB NEW STEEL ASTM A53B WELDED IBSCO	Surface	118.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		10-05-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RG		10-05-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-28-1998 Updated On: 10-28-1998 Review Status: