

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MO682		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WOLFE, JASON						Phone # (715)659-4189		1. Well Location				Fire # (if avail.)			
Mailing Address S3146 STATE RD 13						Town of UNITY						Street Address or Road Name and Number			
City SPENCER				State WI		Zip Code 54479									
County Clark		Co. Permit #		Notification #		Completed 09-29-1998		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) KLINE WELL @ PUMP INC				Lic. # 6010		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address PO BOX 176 LOYAL WI 54446				Well Plan Approval #				°N		°W		Range			
				Approval Date (mm-dd-yyyy)				NW SW Section Township		28 27 N					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.2				2. Well Type New Well					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No				Reason for replaced or reconstructed well ?							
				Hicap Property ? No											
				Hicap Potable ?											
Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 20			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 20 130															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C CLAY				Surface		10									
Y SAND @ GRAVEL				10		50									
Z CLAY @ GRAVEL				50		55									
Y SAND @ GRAVEL				55		95									
D Q DECOMPOSED GRANITE				95		118									
Q GRANITE				118		130									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		18 97LB NEW STEEL ASTM A53B WELDED IBSCO				Surface		118.5							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
11		11				11		11							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
DRILL SLURRY				Surface		20		20							
9. Static Water Level															
15 ft. below ground surface															
10. Pump Test															
Pumping level 40 ft. below surface															
Pumping at 30 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
NONE															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
DK				10-05-1998		10-05-1998									
Drill Rig Operator				Lic or Reg #		Date Signed									
RG				10-05-1998		10-05-1998									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-28-1998

Updated On: 10-28-1998

Review Status: