Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MO836

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOLMES, DAN @ SUSAN	Phone #: (715)258-2357
Mailing Address: 516 N FRANKLIN	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: — Completed: 10-06-1998
Well Constructor (Business Name): SOIK R J PLBG @ HTG INC	Lic. #: 2868 — Facility ID # (Public Wells):
Address: PO BOX 265, STEVENS POINT WI 54481-0265	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.8

1. Well Location

Town of IOLA

Fire # (if avail.):

Street Address or Road Name and Number: JOHNSON RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE NW or Govt Lot #: — Section: 33 — Township: 24 N — Range: 11 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	57

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P	G	HARD PAN @ BOULDERS	Surface	50
		Y		SAND @ GRAVEL	50	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STEEL PIPE P E WELD CONNECTIONS SCH 4018 97 LBS FT ASTM A53 SAWHILL MFG MADE IN USA	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	4 IN JOHNSON S S 12 SLOT	54	57

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SLURRY CLAY	Surface	57	

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WES		10-07-1998
Drill Rig Operator	Lic or Reg #	Date Signed
PF		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Building Overhang		26
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 11-02-1998 Updated On: 11-02-1998 Review Status: