

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MO838		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BEDNAR, DON						Phone # (715)693-1260		1. Well Location				Fire # (if avail.)									
Mailing Address 1208 PINE CREST						Town of MOSINEE															
City MOSINEE						State WI		Zip Code 54455													
County Marathon		Co. Permit #		Notification #		Completed 10-08-1998		Street Address or Road Name and Number 220 CORN RD MOSINEE													
Subdivision Name						Lot #		Block #													
Well Constructor (Business Name) SOIK R J PLBG @ HTG INC				Lic. # 2868		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address PO BOX 265 STEVENS POINT WI 54481-0265				Well Plan Approval #		SE SE		Section 35		Township 27 N		Range 6 E									
						or Govt Lot #															
Approval Date (mm-dd-yyyy)				Well Plan Approval #		SE SE		Section 35		Township 27 N		Range 6 E									
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well													
Reason for replaced or reconstructed well ?				Reason for replaced or reconstructed well ?		Reason for replaced or reconstructed well ?		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled											
Heat Exchange ___ # of drillholes				Hicap Potable ?		Heat Exchange ___ # of drillholes		Hicap Potable ?		Heat Exchange ___ # of drillholes											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		40		Rotary - Mud Circulation		Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary			
6		40		204		Yes		Temp. Outer Casing 9in. dia		Yes		Removed? ___ depth ft. (If NO explain on back side)		P		HARDPAN		Surface		6	
6		40		204		Yes		Temp. Outer Casing 9in. dia		Yes		Removed? ___ depth ft. (If NO explain on back side)		Q		GRANITE		6		204	
6. Casing, Liner, Screen																					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is							
6		NEW BLK STEEL PIPE PE WELD CONNECTIONS SCH 4018 97 LBS FT ASTM A 53 SAWHILL MFG MADE IN USA				Surface		40		15 ft. below ground surface				12 in. above grade							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes							
NONE		NONE				NONE		NONE		Pumping level 190 ft. below surface				Disinfected ? Yes							
NONE		NONE				NONE		NONE		Pumping at 1 GP M for 2 Hrs.				Capped ? Yes							
NONE		NONE				NONE		NONE		Pumping Method ?				Pumping Method ?							
7. Grout or Other Sealing Material																					
Method TREMIE PIPE PRESSURE GROUT																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
NEAT CEMENT GROUT PORTLAND TYPE I				Surface		40		6 S		Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller												Lic #		Date Signed							
WES												WES		10-14-1998							
Drill Rig Operator												Lic or Reg #		Date Signed							
PF												PF		PF							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank	>	25
			POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 01-15-1999

Updated On: 01-15-1999

Review Status: