Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MO840

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, SHERYL	Phone #: (715)335-6259
Mailing Address: 224A ANIWA LN	
City: PLAINFIELD	State: WI Zip Code: 54966
County: Waushara	Co. Permit #:	Notification #:	Completed: 10-27-1998
Well Constructor (Business Name): SOIK R J PLBG @ HTG INC	Lic. #: 2868	Facility ID # (Public Wells):
Address: PO BOX 265 STEVENS POINT WI 54481-0265	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7

1. Well Location

Town of OASIS

Fire # (if avail.):

Street Address or Road Name and Number: W11202 APACHE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.1978 °N -89.4399 °W

Method Code: GCD013

SE NW or Govt Lot #	Section	Township	Range
	21	20 N	9 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	87

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P	G	HARDPAN BOULDERS	Surface	20
		S		SAND	20	45
		C		CLAY	45	75
		Y		SAND GRAVEL	75	87

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STEEL PIPE PE WELD CONNECTIONS SCH 4018 97 LBS PER FT ASTM A53 SAWHILL MFG MADE IN USA	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	6X4 JOHNSON SS 12 SLOT	84	87

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SLURRY CLAY	Surface	87	

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 15 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WES		
Drill Rig Operator	Lic or Reg #	Date Signed
PF		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50

Type	Qualifier	Distance
Building Overhang		13
Septic or Holding, or POWTS Tank	>	25

Comment: WENT 20' FURTHER SEPTIC WAS ABOVE WELL

Created On: 11-23-1998 Updated On: 05-05-2020 Review Status: