Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MO845

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BARRINGTON, KEN	Phone #: (715)344-4079
Mailing Address: 12 HILLCREST DR	
City: STEVENS POINT	State: WI — Zip Code: 54481
County: Portage	Co. Permit #:
Notification #	Completed: 11-03-1998

1. Well Location

Village of PARK RIDGE

Fire # (if avail.)

Street Address or Road Name and Number: 12 HILLCREST DR

Subdivision Name	Lot #	Block #
KACZMIERCZAK	7	2

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
SOIK R J PLBG @ HTG INC	2868	

Latitude / Longitude in Decimal Degree (DD): 44.5198 °N -89.549 °W — Method Code: GCD013

Well Plan Approval #

SW	NW	Section	Township	Range
or Govt Lot #		34	24 N	8 E

Address: PO BOX 265
STEVENS POINT WI 54481-0265

Approval Date (mm-dd-yyyy)

2. Well Type Replacement

of previous unique well # — constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		2.9

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STEEL PIPE PE WELD CONNECTIONS SCH 4018 97LBS PER FT ASTM A53 SAWHILL MFG MADE IN USA	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	X4 JOHNSON SS 12 SLOT	52	55

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WES		
Drill Rig Operator	Lic or Reg #	Date Signed
PF		11-03-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Sewer - Building Sanitary	>	8

Comment:

Created On: 01-19-1999 Updated On: 05-07-2020 Review Status: