Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP194

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WHITE STAG CONST	Phone #: (715)948-2805
Mailing Address: 516 90TH AVE	
City: AMERY	State: WI — Zip Code: 54001
County: Polk	Co. Permit #:
Notification #	Completed: 11-24-1998
Well Constructor (Business Name): MCCULLOUGH @ SONS INC	Lic. #: 44
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 20335 FOREST BLVD N FOREST LAKE MN 55025-9764	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.5	

1. Well Location

Town of GARFIELD

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W — Method Code

NW or Govt Lot #	NW	Section: 14	Township: 33 N	Range: 18 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	67
6	67	112
6	112	140

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	2
		C		CLAY	2	65
	S	N		SOFT SANDROCK	65	112
		N		SANDROCK	112	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53 B SAWHILL 280 WELDED 18 97#	Surface	112
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT	Surface	20	25 S
DRILL MUD	20	67	

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DM		11-25-1998
Drill Rig Operator	Lic or Reg #	Date Signed
DB		11-24-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		70
			Sewer - Building Sanitary		25

Comment:

Created On: 01-19-1999 Updated On: 01-19-1999 Review Status: