Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP195

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: ZAUFT, GARY	Phone #: (715)948-2600
Mailing Address: 975 29TH ST	
City: CLAYTON	State: WI — Zip Code: 54004
County: Polk	Co. Permit #: — Notification #: — Completed: 11-25-1998
Well Constructor (Business Name): MCCULLOUGH @ SONS INC	Lic. #: 44 — Facility ID # (Public Wells):
Address: 20335 FOREST BLVD N, FOREST LAKE MN 55025-9764	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location
Town of CLAYTON
Fire # (if avail.):
Street Address or Road Name and Number: 975 29TH
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
NW NW or Govt Lot # — Section: 22 — Township: 33 N — Range: 15 W

2. Well Type Reconstruction
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	55
6	55	86

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	2
		Y		SAND GRAVEL	2	45
		Z		CLAY GRAVEL	45	50
		C		CLAY	50	53
	S	N		SOFT SANDROCK	53	55
	H	L		HARD LIME ROCK	55	86

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA 53B SAWHILL 280 WELDED 18 97#	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT	Surface	20	2.5 S
DRILL MUD	20	55	

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DM		11-25-1998
Drill Rig Operator	Lic or Reg #	Date Signed
DB		11-25-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		90	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-19-1999 Updated On: 01-19-1999 Review Status: