

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MP197		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner HAMMONS, GREGORY						Phone # (715)948-2060		1. Well Location				Fire # (if avail.)	
Mailing Address 63 60TH AVE						Town of CLEAR LAKE							
City CLAYTON						State WI		Zip Code 54004				Street Address or Road Name and Number 63 60TH AVE	
County Polk		Co. Permit #		Notification #		Completed 11-30-1998		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) MCCULLOUGH @ SONS INC				Lic. # 44		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 20335 FOREST BLVD N FOREST LAKE MN 55025-9764				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 2 32 N 15 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? OLD WELL IS NO GOOD							
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled							
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 63			Yes Rotary - Mud Circulation										
2 63 69			Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)							
I TOP SOIL			Surface 2										
Z CLAY GRAVEL			2 25										
S SAND			25 50										
G GRAVEL			50 69										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
4		ASTMA53B KOREA SEHA 237 T C 1143				Surface 63							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
2		STAINLESS STEEL SCREEN 12 SLOT				63 69							
7. Grout or Other Sealing Material													
Method TREMIE PRESSURE													
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement									
BENTONITE GROUT		Surface 20		2 S									
DRILL MUD		20 63											
9. Static Water Level													
25 ft. below ground surface													
10. Pump Test													
Pumping level 55 ft. below surface													
Pumping at 10 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
BILL PUMP SEALING WELL													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
DM								12-01-1998					
Drill Rig Operator						Lic or Reg #		Date Signed					
DB								11-30-1998					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		12
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-19-1999

Updated On: 01-19-1999

Review Status: