

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MP873		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BAUMAN, SHARON						Phone # (608)372-5388		1. Well Location				Fire # (if avail.)					
Mailing Address 12503 CO N						Town of BYRON						Street Address or Road Name and Number 12503 CO N TOMAH					
City TOMAH				State WI		Zip Code 54660											
County Monroe		Co. Permit #		Notification #		Completed 07-21-1998		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) NOTH WELL DRILLING				Lic. # 6282		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9924 °N -90.4035 °W			Method Code GCD013				
Address 26042 CO HWY G TOMAH WI 54660				Well Plan Approval #				NW SE		Section 32		Township 18 N		Range 1 E			
				Approval Date (mm-dd-yyyy)				or Govt Lot #		32		18 N		1 E			
Hicap Permanent Well #			Common Well #			Specific Capacity 0.4				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of Private, potable						Hicap Well ? No											
Heat Exchange ___ # of drillholes						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
8 Surface 49			Rotary - Mud Circulation														
6 49 60			Rotary - Air														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Yes Cable-tool Bit 8in. dia... No														
			Dual Rotary														
			Yes Temp. Outer Casing 9in. dia														
			Yes Removed? 18depth ft. (If NO explain on back side)														
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
T - S -				BRN SAND				Surface		18							
T - N -				BRN SANDSTONE				18		45							
I - N -				WHITE SANDSTONE				45		60							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		SAWHILL ASTM A53B 6.625 X .280 HEAT # 950319 WELDED JOINTSHOE				Surface		49									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material										9. Static Water Level							
Method GROUT PUMP TREMIE PIPE										22 ft. below ground surface							
Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement PORTLAND CEMENT Surface 49 22 S										10. Pump Test				11. Well Is			
										Pumping level 55 ft. below surface				Developed ? Yes			
Pumping at 12 GP M for 24 Hrs.				Disinfected ? Yes													
Pumping Method ?				Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE										13. Constructor / Supervisory Driller				Lic #		Date Signed	
										TM						07-28-1998	
										Drill Rig Operator				Lic or Reg #		Date Signed	
TEN						07-28-1998											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		24
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 12-09-2004

Updated On: 04-29-2020

Review Status: