Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP873

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BAUMAN, SHARON	Phone #: (608)372-5388
Mailing Address: 12503 CO N	
City: TOMAH	State: WI — Zip Code: 54660
County: Monroe	Co. Permit #: — Notification #: — Completed: 07-21-1998
Well Constructor (Business Name): NOTH WELL DRILLING	Lic. #: 6282 — Facility ID # (Public Wells):
Address: 26042 CO HWY G, TOMAH WI 54660	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of BYRON

Fire # (if avail.):

Street Address or Road Name and Number: 12503 CO N TOMAH

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.9924 °N -90.4035 °W — Method Code: GCD013

NW SE or Govt Lot #: — Section: 32 — Township: 18 N — Range: 1 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	49
6	49	60

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 8in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing 9in. dia
- Yes Removed? 18depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - S -	BRN SAND	Surface	18
T - N -	BRN SANDSTONE	18	45
I - N -	WHITE SANDSTONE	45	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL ASTM A53B 6.625 X .280 HEAT # 950319 WELDED JOINTSHOE	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GROUT PUMP TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	49	22 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM		07-28-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TEN		07-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		24
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 12-09-2004 Updated On: 04-29-2020 Review Status: