

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MP874		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BENZINS, IVAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 18843 CENTURY AVE								Town of GRANT											
City WARRENS						State WI		Zip Code 54666											
County Monroe		Co. Permit #		Notification #		Completed 05-27-1998		Subdivision Name				Lot #							
								Block #											
Well Constructor (Business Name) NOTH WELL DRILLING				Lic. # 6282		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1077 °N -90.6111 °W									
						Well Plan Approval #				Method Code GCD013									
Address 26042 CO HWY G TOMAH WI 54660						Approval Date (mm-dd-yyyy)				NW SW Section Township Range or Govt Lot # 22 19 N 2 W									
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type Replacement of previous unique well # constructed in									
Reason for replaced or reconstructed well ? WELL POINT																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock									
8		Surface		40															
6		40		60		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 8in. dia... No Dual Rotary Yes Temp. Outer Casing 9in. dia Yes Removed? 2depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				12 in. above grade					
6		SAWHILL ASTM A53B 6.625 X .280 HEAT # 950319 WELDED JOINT& DRIVE SHOE				Surface		40											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
										Pumping level 50 ft. below surface Pumping at 12 GP M for 24 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method GROUT PUMP TREMIE PIPE																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No OWNER WILL											
PORTLAND CEMENT		Surface		40		14 S													
13. Constructor / Supervisory Driller														Lic #		Date Signed			
TM																06-08-1998			
Drill Rig Operator														Lic or Reg #		Date Signed			
TEN																06-08-1998			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61	Building Overhang		13
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 12-09-2004

Updated On: 04-29-2020

Review Status: