

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MP875		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner KUBE, JOSEPH						Phone # (608)372-5352		1. Well Location				Fire # (if avail.)											
Mailing Address 23560 HERITAGE AVE						Town of TOMAH																	
City TOMAH						State WI		Zip Code 54660															
County Monroe		Co. Permit #		Notification #		Completed 09-09-1998		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) NOTH WELL DRILLING				Lic. # 6282		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9447 °N -90.5211 °W				Method Code GCD013									
Address 26042 CO HWY G TOMAH WI 54660				Well Plan Approval #		SW SE		Section 17		Township 17 N		Range 1 W											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				2. Well Type New Well													
Heat Exchange ___ # of drillholes						Hicap Well ? No				of previous unique well # constructed in													
Private, potable						Hicap Property ? No				Reason for replaced or reconstructed well ?													
Hicap Potable ?						Construction Type Drilled																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		83		Rotary - Mud Circulation								- - X -		CLAY & SAND		Surface		16			
6		83		235		Rotary - Air								T - N -		BRN SANDSTONE		16		83			
						Rotary - Air & Foam								T - N -		LIGHT BRN SANDSTONE		83		235			
						Drill-Through Casing Hammer																	
						Reverse Rotary																	
						<u>Yes</u> Cable-tool Bit 8in. dia...								<u>No</u>									
						Dual Rotary																	
						<u>Yes</u> Temp. Outer Casing 9in. dia																	
						<u>Yes</u> Removed? 16depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		190 ft. below ground surface				12 in. above grade									
6		SAWHILL A53B 6.6250 .280 HEAT # 950319 WELDED JOINT X DRIVE SHOE				Surface		83		10. Pump Test				Developed ? Yes									
										Pumping level 215 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 12 GP M for 24 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method GROUT PUMP TREMIE PIPE														Filled & Sealed Well(s) as needed? NONE									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
PORTLAND CEMENT				Surface		83		23 S		TM						09-22-1998							
										Drill Rig Operator				Lic or Reg #		Date Signed							
										TEN						09-22-1998							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		74	Building Overhang		23
			Septic or Holding, or POWTS Tank		68

Comment:

Created On: 12-09-2004

Updated On: 04-29-2020

Review Status: