Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP875

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUBE, JOSEPH	Phone #: (608)372-5352
Mailing Address: 23560 HERITAGE AVE	
City: TOMAH	State: WI — Zip Code: 54660
County: Monroe	Co. Permit #: — Notification #: — Completed: 09-09-1998
Well Constructor (Business Name): NOTH WELL DRILLING	Lic. #: 6282 — Facility ID # (Public Wells):
Address: 26042 CO HWY G, TOMAH WI 54660	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of TOMAH

Fire # (if avail.):

Street Address or Road Name and Number: 23560 HERITAGE AVE TOMAH WI

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.9447 °N -90.5211 °W — Method Code: GCD013

SW SE or Govt Lot #: — Section: 17 — Township: 17 N — Range: 1 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	83
6	83	235

Upper Enlarged Drillhole — Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 8in. dia... No

Dual Rotary .....

Yes Temp. Outer Casing 9in. dia

Yes Removed? 16depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	-	CLAY & SAND	Surface	16
T	-	N	-	BRN SANDSTONE	16	83
T	-	N	-	LIGHT BRN SANDSTONE	83	235

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL A53B 6.6250 .280 HEAT # 950319 WELDED JOINT X DRIVE SHOE	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

190 ft. below ground surface

10. Pump Test

Pumping level 215 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GROUT PUMP TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	83	23 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM		09-22-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TEN		09-22-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		74	Building Overhang		23
			Septic or Holding, or POWTS Tank		68

Comment:

Created On: 12-09-2004 Updated On: 04-29-2020 Review Status: