Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP877

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRUNNER, WILLIAM	Phone #: (608)565-7740
Mailing Address: 3004 CRESCENT RD	
City: WARRENS	State: WI — Zip Code: 54666
County: Monroe	Co. Permit #: — Notification #: — Completed: 12-12-1998

1. Well Location

Town of SCOTT

Fire # (if avail.):

Street Address or Road Name and Number: 3004 CRESCENT RD WARRENS

Subdivision Name: — Lot #: — Block #: —

Well Constructor (Business Name): NOTH WELL DRILLING	Lic. #: 6282	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 44.1271 °N -90.332 °W — Method Code: GCD013
		Well Plan Approval #:	SW SW or Govt Lot #: — Section: 13 — Township: 19 N — Range: 1 E
Address: 26042 CO HWY G TOMAH WI 54660		Approval Date (mm-dd-yyyy):	**2. Well Type** Replacement
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	of previous unique well #: — constructed in: —
3. Well serves 1 # of		Hicap Well ? No	Reason for replaced or reconstructed well ?: WELL POINT
Private,potable		Hicap Property ? No	
Heat Exchange____# of drillholes		Hicap Potable ?	Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	67

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Y	-	BRN SAND & GRAVEL	Surface	35
I	S	N	-	WHT SOFT SANDSTONE	35	60
I	H	N	-	WHT FIRM SANDSTONE	60	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL A53B 6.625 X .280 HEAT # 950319 WELDED JOINT & DRIVE SHOE	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: BENTONITE CRUMBLES DRIVEN FROM SURFACE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MOUNDED BENTONITE CRUMBLES	Surface	60	6 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

OWNER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM		12-28-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TEN		12-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		35
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-09-2004 Updated On: 04-29-2020 Review Status: