Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MP877

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRUNNER, WILLIAM		Phone #: (608)565-7740
Mailing Address: 3004 CRESCENT RD		
City: WARRENS	State: WI	Zip Code: 54666

County	Co. Permit #	Notification #	Completed
Monroe			12-12-1998

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
NOTH WELL DRILLING	6282	

Address: 26042 CO HWY G, TOMAH WI 54660

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.3

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of SCOTT

Fire # (if avail.):

Street Address or Road Name and Number: 3004 CRESCENT RD WARRENS

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.1271 °N -90.332 °W	GCD013

SW SW or Govt Lot #	Section	Township	Range
	13	19 N	1 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WELL POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	67

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Y	-	BRN SAND & GRAVEL	Surface	35
I	S	N	-	WHT SOFT SANDSTONE	35	60
I	H	N	-	WHT FIRM SANDSTONE	60	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL A53B 6.625 X .280 HEAT # 950319 WELDED JOINT & DRIVE SHOE	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: BENTONITE CRUMBLES DRIVEN FROM SURFACE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MOUNDED BENTONITE CRUMBLES	Surface	60	6 S

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 12 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
OWNER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
TM		12-28-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TEN		12-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		35
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 12-09-2004 Updated On: 04-29-2020 Review Status: