

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				MQ320		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RAHLF, ROBB						Phone # (715)536-7766		1. Well Location				Fire # (if avail.)			
Mailing Address N575 HILLY RD						Town of SCOTT						N575			
City MERRILL						State WI		Zip Code 54452				Street Address or Road Name and Number HILLY RD			
County Lincoln		Co. Permit #		Notification #		Completed 09-30-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) JAMES A HORNUMG SR				Lic. # 695		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.1371 °N -89.7865 °W				Method Code GCD013	
Address W4014 ALPINE AVE MERRILL WI 54452-9064				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 30 31 N 6 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME Construction Type Drilled					
						Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		120											
						Rotary - Mud Circulation									
						Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S		U		MUDDY SAND				Surface		70					
D		Q		DECOMPOSED GRANITE				70		75					
K		Q		BLACK GRANITE				75		120					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STD BLACK SAWHILL ASTMA53B WELDED				Surface		75							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method NONE															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NONE				Surface											
9. Static Water Level															
30 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface															
Pumping at 5 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NONE															
13. Constructor / Supervisory Driller										Lic #		Date Signed			
JH												09-30-1998			
Drill Rig Operator										Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		20
Building Overhang		15	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-04-1999

Updated On: 06-15-2020

Review Status: