Well Construction Report
WISCONSIN UNIQUE WELL NUMBER MQ321

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GAEDE, VALITHA			Phone #: (715)536-3253
Mailing Address: 300 S PARK			
City: MERRILL	State: WI	Zip Code: 54452	
County: Lincoln	Co. Permit #:	Notification #:	Completed: 10-08-1998

Well Constructor (Business Name): JAMES A HORNUNG SR	Lic. #: 695	Facility ID # (Public Wells):	
Address: W4014 ALPINE AVE MERRILL WI 54452-9064		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SCHLEY

Fire # (if avail.)

Street Address or Road Name and Number: TOWN HALL RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SW NE or Govt Lot #	Section: 9	Township: 32 N	Range: 8 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	140

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	M	SAND & SILT	Surface	22
	D	Q		DECOMPOSED GRANITE	22	24
G		Q		GRAY GRANITE	24	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL BLK WELDED ASTMA53B	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method DISPLACEMENT PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT GROUT	Surface	40	5 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 130 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH		10-08-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		50	Sewer - Building Sanitary		75
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 12-06-1999 Updated On: 12-06-1999 Review Status: